



Product certificate K-0222323-1

Issued 2025-02-01

Replaces --

Page 1 of 2

Internal coatings of steel tanks for the storage of flammable fluids - Transpoxy Masterbond BT

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Zandleven Coatings B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K779/04 "Internal coatings of steel tanks for the storage of flammable fluids" dated 2010-07-15 inclusive amendment sheet dated 2015-03-15.

SCOPE

The product is tested and suitable for flammable fluids as mentioned on page 2 of this certificate.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.com

Supplier

Zandleven Coatings B.V.
Snekertrekweg 57-59
8912 AA LEEUWARDEN
The Netherlands
Tel. +31 58-2129545
info@zandleven.com
www.zandleven.com

Certification process
consists of initial and
regular assessment of:

- quality system
- product



Internal coatings of steel tanks for the storage of flammable fluids – Transpoxy Masterbond BT

TECHNICAL SPECIFICATION

Internal epoxy coatings in accordance with Evaluation Guideline BRL-K779/04 "Internal coatings of steel tanks for the storage of flammable fluids" dated 2010-07-15 and amendment sheet dated 2015-03-15.

Coating Type

Transpoxy Masterbond BT satisfies the requirements of BRL-K779.

APPLICATION AND USE

The product is suitable for application as an internal coating system of steel tanks suitable for the storage of PGS ~~Class 1, Class 2~~ or Class 3 flammable fluids at a maximum storage temperature of -20°C to +40°C.

- a) Hydrotreated Vegetable Oils (HVO) - 100%;
- b) Biodiesel containing up to 100% FAME (B100);
- c) Diesel Exhaust Fluid (AdBlue, AUS 32).

MARKING

The products are marked with the Kiwa-mark.

Place of mark: on the outside of the packaging, containers or bags

Compulsory specifications:

- the maximum shelf life of the product must be specified
- **Kiwa K-0222323**
- name of the manufacturer.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Zandleven Coatings B.V.
- and, if necessary,
- Kiwa Nederland B.V.

For the correct method of storage, transport and processing, please refer to the instructions of the certificate holder.